




Grease Sampling Kit for Pillow Block Bearings MGT-01-008

Directions for sampling with the Grease Thief from Pillow Block Bearings:

Enclosed in the kit:

- Eight (8) sleeves containing:
 - One (1) 10cc plastic syringe
 - One (1) plastic spatula
 - One (1) Grease Thief with yellow cap
 - One (1) Shipping Tube
 - One (1) Blank Equipment Label
 - One (1) shipping envelopes
1. Remove yellow cap from Grease Thief and place back into bag to keep clean.
 2. Remove plunger from syringe and place back into bag to keep clean
 3. Use wide end of spatula to remove any dirt or debris.
 4. Use narrow end of spatula to sample grease from desired test area
 5. Place grease from spatula into plastic syringe. Approximately 1.5 grams of grease or about 2 cc are needed to completely fill the Grease Thief.
 6. Inject the grease from the syringe into the Grease Thief to push the plunger to the far end as the grease fills the body. The Grease Thief is completely full when the grease just begins to exit at the relief holes. While grease is being added, it is necessary to slowly withdraw the syringe tip from within the Grease Thief body to completely fill the open end.



7. Prior to placing the yellow cap onto the Grease Thief for shipment, purge a small portion of the grease from the Grease Thief into the yellow cap to relieve any pressure build up from placing the cap on the full Grease Thief.
8. Once a small portion of the grease is in the yellow cap, firmly place the yellow cap on the Grease Thief. This will ensure the Grease Thief is full and no sample is lost through the purge holes.
9. Place the filled and capped Grease Thief into the shipping tube that is provided.
10. Fill out the blank equipment label with all needed information and affix to the shipping tube for proper identification of the sample.
11. Dispose of the syringe and spatula
12. Place the Grease Thief inside a shipping tube.
13. Place the shipping tube inside the shipping envelope and affix the proper postage.
14. Send to the lab for analysis.

Please Note that if the Grease Thief is not completely filled, it may not be possible to complete all the tests in the test slate. Analysis will be performed on as many tests as possible given the submitted volume. If only small quantities are available, customer should provide priorities for performance of individual tests in the test slate.

Also available for Grease Thief:

MGT-01-012 Kit for Electric Motor Bearing

MGT-01-014 Kit for MOV and Gearbox Sampling

MGT-01-018 Grease Sampler Adjustable T-Handle

MGT-01-001 Grease Sampler Metal Double
Extension T-Handle

MGT-01-081 Kit for Robot Drive Gear Sampling

MGT-01-067 Kit for Wind Turbine Sampling



410 Kings Mill Road
York, PA 17401 USA
Phone: 1-717-843-8884
Fax: 1-425-696-8725
www.mrgcorp.com